

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0328:0181 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Models CSL24W, CSL24C, CSL24CH, CSLB24 and *CSLB120 strobe lights. All models may be followed by -A(amber), -B(blue), -G(green), or -R(red) denoting the color of the lens. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Intended for indoor use only. Model CSLB24 and *CSLB120 may be used for an outdoor installation with listed back box Model SBX-1 and 4BX-1.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as a strobe for use with separately listed compatible fire alarm control units. Models CSL24W and CSLB24 intended for wall mount only. Models CSL24C and CSL24CH intended for ceiling mount only. Refer to listee's Installation Instruction Manual for details.

NOTE:

1. Not to be used as visual public mode alarm notification appliance.
2. Not suitable for the hearing-impaired applications.

*Rev 8-28-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2012**

Listing Expires **June 30, 2013**

Authorized By: **JASON DEWITT, Deputy State Fire Marshal**
Fire Engineering Division